



## SPECIFICATION:

### AACERFLEX, *Floating System*

## **AacerFlex, Floating Floor**

### **SECTION 09642-Wood Gymnasium Flooring**

#### **PART 1 – GENERAL**

##### **1.1. DESCRIPTION**

###### **A. Related work specified under other sections.**

###### **1. CONCRETE SUBFLOORS – SECTION 03**

- a. Slab depression is:
  - 2-1/4" (57mm) for 25/32" (20mm) flooring with 1/2" (12mm) pad
  - 2-1/2" (64mm) for 25/32" (20mm) flooring with 3/4" (19mm) pad
- b. The general contractor shall furnish and install the concrete subfloor depressing the slab sufficiently to accommodate the floor system. The slab shall be steel troweled smooth to a tolerance of 1/8" (3mm) in any 10' (3m) radius by the general contractor. High spots shall be ground level, and low spots filled in with approved leveling compound by the general contractor to the full approval of the flooring contractor.
- c. Floor Flatness and Floor Levelness (FF and FL) numbers are not recognized.
- d. The concrete substrate shall be deemed fully cured by industry standards through field testing moisture content of concrete using embedded Relative Humidity testing probes. Concrete RH of 85% or less shall be achieved prior to installing subfloor components when including a standard 6-mil (0.15mm) vapor retarder.
- f. The standard concrete surface vapor retarder, or heavier-duty surface vapor retarder only serves to address remaining vapor in a substantially cured slab. Concrete surface vapor retarders are not included to address free moisture, such as high-water tables, poor drainage, ground water, leaking pipes, etc. Aacer Sports Flooring and the flooring contractor accept no responsibility related to such free moisture.

###### **2. MEMBRANE WATERPROOFING-SECTION 07**

- a. Concrete subfloors on or below grade shall be adequately waterproofed beneath the slab and at the perimeter walls and on earth side of below grade walls by general contractor using suitable type membrane.
- b. Sand-Poly-Sand slab construction is not an acceptable construction.

###### **3. THRESHOLDS – SECTION 08**

###### **4. SLEEVES AND STANDARD INSERTS – SECTION 11**

##### **1.2. REFERENCES**

- A. FSC – Forest Stewardship Council™**
- B. MFMA – Maple Flooring Manufacturers Association**

##### **1.3. QUALITY ASSURANCE**

###### **A. Manufacturer**

1. Manufacturer of resilient flooring shall be a firm specializing in manufacturing products specified in this section.
2. Basis of design shall be "AacerFlex" sports floor system as provided by **Aacer Sports Flooring. (877) 582-1181, [www.Aacerflooring.com](http://www.Aacerflooring.com).**

## **AacerFlex, Floating Floor**

3. Materials other than those listed must be approved 10 days prior by written addendum. Materials from non-approved manufacturers will not be accepted.

### **B. Installer**

1. The installation of the floor system described in these specifications shall be completed by a firm familiar with the requirements of the system specified and fully experienced in procedures required for installing athletic flooring manufactured by Aacer Sports Flooring.
2. Flooring Contractor shall be liable for all matters related to installation for a period of one year after the floor has been substantially installed and completed.
3. Installer shall have Aacer installation accreditation.
  - a. Optional: MFMA accreditation.(Specify or Delete)

### **C. Performance Testing**

1. Flooring system shall have been independently tested to the International Standards: DIN 18032, Part 2, and/or EN 14904.
2. Independent testing laboratory shall have Scientific Body Membership in the International Association of Sports Surface Sciences (ISSS).

### **1.4. SUBMITTALS**

- A. **Specification** - Submit Aacer Sports Flooring specification sheets and shop drawings as required.
- B. **Sample** - Submit required number of samples of the specified system as requested by the owner/architect.
- C. **Maintenance Guidelines** - Upon completion of floor, send the Aacer Floor Maintenance Guide to the owner. This guide will explain the proper HVAC and building maintenance requirements as well as floor cleaning and servicing guidelines to assure proper floor performance and longevity.

### **1.5. WORKING CONDITIONS**

- A. The wood flooring and its components specified herein shall not be delivered or installed until all wet trades and overhead work is completed. This includes all masonry, painting, plaster, tile, marble, and terrazzo, as well as all overhead mechanical trades. The building shall be fully enclosed and weather tight and all permanent windows and doorways shall be installed.
- B. The concrete substrate shall be determined fully cured by industry standards and materials shall not be stored at the installation location unless the in-slab relative humidity level for the concrete slab is 85% or lower before installation. The concrete slab shall be free of all foreign materials and broom cleaned by the General Contractor when turned over to the floor installer.
- C. Permanent HVAC units for the building shall have been operating a minimum of one week prior to the floor installation start up.
- D. During and after installation, the H.V.A.C. system should be complete, operational, and conditioning air to be within **55/75 degrees Fahrenheit (13-27 degrees Celsius) with relative humidity between 35/50 percent** or to conditions expected following installation and during occupancy.

## **AcerFlex, Floating Floor**

- E.** Flooring must be stored on site in a dry, well-ventilated area while acclimating to site conditions. Moisture content of wood shall be consistent with the ambient conditions of the building as it will be maintained when occupied.

### **1.6. WARRANTY AND DISCLAIMER**

- A.** Acer Wood Floors Crandon, WI hereby warrants the materials it has supplied to be free from manufacturing defects for a period of one year. This warranty is in lieu of and excludes all other warranties expressed or implied including any implied warranties of merchantability or fitness for a particular purpose. Guarantee shall not cover damage caused in whole or in part by casualty, ordinary wear and tear, abuse, use for which material is not designed, faulty construction of the building, settlement of the building walls, failure of the other contractors to adhere to specifications, separation of the concrete slab and excessive dryness or excessive moisture from humidity, spillage, migration through the slab or wall, or any other source.
- B.** During the warranty period, the floor shall not be recoated without the approval of the flooring contractor.
- C.** The jobsite documentation forms by the flooring contractor shall become a part of the warranty and both the owner and flooring contractor shall retain record of said forms as a permanent reference for any abrogation.
- D.** Flooring contractor warrants the install of the floor systems to be free from defects in materials and workmanship for a period of one year.
- E.** Notification of claim shall be made within 30 days of discovery.
- F.** In the event of breach of any warranty, the liability of Acer Sports Flooring shall be limited to repairing or replacing **AcerFlex** material and system components supplied by Acer Sports Flooring and proven to be defective in manufacture, and shall not include any other damages, either direct or consequential.
- G.** It is the policy of Acer Sports Flooring to continuously improve its line of products. Therefore, Acer Sports Flooring reserves the right to change, modify, or discontinue systems, specifications, and accessories of all products at any time without notice or obligation to purchaser.

## **PART 2 PRODUCTS**

### **2.1. MATERIALS**

- A. Vapor Barrier** – 6 mil (0.15mm) polyethylene
- B. Resilient Pads-**
  - 1. Acer 1/2" (12mm) TriPower® EPDM resilient pad
  - 2. Optional Pads (Specify or Delete): 3/4" (19mm) TriPower® EPDM pads:
    - a. Black 60 durometer
    - b. Blue 50 durometer
    - c. Red 70 durometer
  - 3. Optional Pad (Specify or Delete): Acer 1/2" (12mm) ECO recycled rubber pad
  - 4. Optional Pad (Specify or Delete): Acer 3/4" (19mm) ECO recycled rubber pad
- C. Subfloor –**
  - 1. 2 layers of 15/32" (12mm) APA rated plywood or manufacturer's approved sheathing. Exposure 1.
  - 2. FSC® Certified (Specify or Delete) Subfloor must be certified by the Forest Stewardship Council™
- D. Automatic Mechanical Ventilation- (Optional)(Specify or Delete)**
  - 1. Acer "PowerVent Advanced" Air Flow System

## **AacerFlex, Floating Floor**

- a. 3" x 12" air duct, attached blowers capable of at least 300 C.F.M. and a control box with smart humidistats.

2. Aacer Original PowerVent Air Flow System

- a. 3" X 12" air duct, attached blowers capable of at least 300 C. F. M. and an in - floor humidistat.

**E. Flooring –**

1. 25/32" x 2-1/4" (20mm x 57mm) 2<sup>nd</sup> and Better grade northern Hard Maple flooring, TGEM, MFMA grade marked and stamped as manufactured by Aacer Wood Floors.
2. Optional Sizes and Grades (Specify or Delete)
  - a. 25/32" x 1-1/2" (20mm x 38mm)
  - b. 1<sup>st</sup> grade, 3<sup>rd</sup> grade, 3<sup>rd</sup> and better grade
3. FSC® Certified (Specify or Delete) Maple must be certified by the Forest Stewardship Council™
4. Expansion Bead (Specify or Delete) Flooring shall include 1/64" Expansion Bead.

**F. Fasteners –**

1. Flooring – 1-3/4" (44mm) or 2" (51mm) barbed cleats or staples.
2. Subfloor – 1" (25mm) coated staples or equivalent.

**G. Finish Materials –** MFMA approved seal and finish.

**H. Game Lines –** Compatible with finish colors as specified by layout design.

**I. Wall Base -** Heavy duty, molded, vented cove base with pre-molded outside corners.

## **PART 3 - EXECUTION**

### **3.1. PRE-INSTALLATION INSPECTION**

- A. Floor installer shall verify slab tolerance of concrete and report any needed corrections to general contractor.
- B. Room shall be broom cleaned and free of any foreign debris.
- C. Floor installer shall document site and working conditions prior to and during installation. This documentation shall become a part of any warranty and may or may not affect fulfillment of any warranty.

### **3.2. INSTALLATION**

#### **A. SUBFLOOR –**

1. Cover entire slab with vapor retarder, sealing and lapping joints a minimum of 6" (152mm).
2. AacerFlex panels shall be laid perpendicular to finished flooring. (Optional laid at 45-degree angle) Allow 1/4" (6mm) space between ends of abutted panels and stagger joints 4' (1219mm). Aacer Performance pads shall be installed on underside of bottom layer 12" (305mm) on center, 32 per sheet. Install solid blocking under bleachers in the stacked position. Install stop blocking under bleachers in the extended position or heavy load areas as required. Provide 1-1/2" (38mm) expansion void at perimeter and all vertical obstructions.
3. Install second layer of plywood material laid diagonally at 45-degree angles over the first layer with 1/4" (6mm) spacing on all edges, breaking rows at 4' (1219mm). Second layer

## **AacerFlex, Floating Floor**

shall be attached using 1" (25mm) coated staples or equivalent, at a minimum of 12" (305mm) on center.

4. If laying first layer at 45-degree angle, lay second layer at opposite 45-degree angle.
5. Provide 1-1/2" (40mm) to 2" (51mm) expansion voids at perimeter and all vertical obstructions. Install solid blocking at doorways, under bleachers in the stacked position, and below portable goals.

### **B. MAPLE FLOORING**

1. Install Aacer Wood Floors maple flooring parallel with the long dimension of room. Flooring shall be power nailed or stapled approximately 12" (305mm) on center with all end joints properly driven tight.
2. Expansion joints may be required between flooring strips intermittently throughout the floor. Requirements determined by site and geographical conditions.
3. Provide 1-1/2" (40mm) to 2" (51mm) expansion void at all walls and permanent obstructions.

### **3.3.FINISHING**

#### **A. FLOOR SANDING**

1. Machine sand entire floor with multiple grit papers to a smooth and uniform surface, free from edger marks and drum drops.
2. Remove all sanding dust and lint from entire surface by vacuum and/or tack.

#### **B. FINISHING AND GAME LINES**

1. Inspect entire floor to be sure surface is ready to accept seal and finish. Floor should be free from dust and debris.
2. Apply (2) coats of approved seal and (2) coats of approved finish per manufacturer's label instructions.
3. Floor shall be buffed, cleaned, and tacked between coats.
4. Apply game lines and logos as indicated by drawings between seal and finish coats. Paint shall be compatible with finish.

#### **C. BASE INSTALLATION**

1. Install vent cove base with cove base adhesive and/or mechanical attachment to wall. Use pre-molded outside corners and mitered inside corners.

### **3.4.CLEANUP**

#### **A. CLEANUP**

1. Remove excess debris and waste material from the work area.
2. General Contractor shall lock floor area after floor is finished to allow proper curing time. If general contractor or owner requires use of gym before proper curing time, they shall protect the floor by covering with non-marring Kraft paper.

**END OF SECTION 09642**

AacerFlex Specification  
Revision Level A 2024

## **AcerFlex, Floating Floor**

*Note:*

*Construction options are available to modify this system to the project design and budget.*

*Contact your Regional Sales Manager (1-877-582-1181) or the local Acer Sports Flooring Authorized Dealer for more information.*